



Source : <https://www.sortirdunucleaire.org/Etats-Unis-Millstone-urgence-declaree-suite-au>

Réseau Sortir du nucléaire > Informez

vous > Des accidents nucléaires partout > **Etats-Unis : Millstone : urgence déclarée suite au déclenchement d'une alarme incendie en zone contrôlé du réacteur n°2**

15 août 2017

Etats-Unis : Millstone : urgence déclarée suite au déclenchement d'une alarme incendie en zone contrôlé du réacteur n°2

L'urgence a été déclarée car l'état de zone n'a pu être établi dans les 15 minutes requises par les textes. Les paramètres de l'enclencheur n'indiquent pas d'incendie et une entrée dans la zone est programmée pour vérifier l'absence d'incendie. Le réacteur est toujours à 100 % de sa puissance. L'alerte a été levée 2 h après son déclenchement suite à l'absence d'incendie et la recherche de la cause du déclenchement de l'alarme est en cours.

Type : PWR - Puissance : 2 700 MW - Première divergence : 10 / 1975 -

Available in english only

Event Number : 52904

Facility : MILLSTONE

State : CT - Unit : [2] - RX Type : [2] CE

Event Date : 08/15/2017 - Event Time : 07:48 [EDT]

Last Update Date : 08/15/2017 Emergency Class : **UNUSUAL EVENT** 10 CFR Section : 50.72(a) (1) (i) - **EMERGENCY DECLARED**

Initial PWR : 100 % Current PWR : 100 %

Event Text

UNUSUAL EVENT DUE TO FIRE ALARM IN CONTAINMENT

On August 15, 2017 at 0748 EDT, an Unusual Event was declared at Millstone Unit 2 due to a fire alarm indication in containment that was unable to be verified extinguished within 15 minutes.

Current containment parameters do not indicate an actual fire. A containment entry is planned to verify that there is no fire. Unit 2 continues at 100% power. Unit 3 was unaffected. The NRC remains in Normal mode.

The licensee notified the NRC Resident Inspector and State and local government agencies.

Notified DHS SWO, FEMA Ops Center, DHS NICC. Notified FEMA National Watch and Nuclear SSA via E-mail.

* * * UPDATE FROM TODD STRINGFELLOW TO DONALD NORWOOD AT 0953 EDT ON 8/15/2017 * * *

At 0951 EDT, the Unusual Event was terminated. No signs of an actual fire were present upon containment entry. All alarms are cleared and they are investigating the cause of the alarm.

The licensee notified the NRC Resident Inspector and State and local government agencies.

Notified R1DO (Gray), NRR EO (Miller), and IRD (Gott). Notified DHS SWO, FEMA Ops Center, DHS NICC. Notified FEMA National Watch and Nuclear SSA via E-mail.