



Source : <https://www.sortirdunucleaire.org/Etats-Unis-Turkey-point-Urgence-declaree-pour-les>

Réseau Sortir du nucléaire > Informez

vous > Des accidents nucléaires partout > **Etats-Unis : Turkey point : Urgence déclarée pour les 2 réacteurs suite à l'approche d'un ouragan**

7 September 2017

# Etats-Unis : Turkey point : Urgence déclarée pour les 2 réacteurs suite à l'approche d'un ouragan

Les choses se seraient passées correctement durant l'ouragan.

▶ Type : PWR - Puissance : 2 300 MWth - Première divergence : n° 3 : 10 /1972 - n°4 : 06 / 1973 -

*Available in english only*

Facility: TURKEY POINT

State: FL - Unit: [3] [4] - RX Type: [3] W-3-LP,[4] W-3-LP

Event Date: 09/07/2017

Event Time: 23:14 [EDT]

Emergency Class: **UNUSUAL EVENT**

10 CFR Section:

50.72(a) (1) (i) - **EMERGENCY DECLARED**

50.72(b)(2)(xi) - OFFSITE NOTIFICATION

Initial PWR n° 3 : 100 % - n° 4 : 100 %

Current PWR n° 3 : 100 % - n° 4 : 100 %

Event Text

## **NOTIFICATION OF UNUSUAL EVENT - HURRICANE WARNING**

"At 2300 today, the National Weather Service issued a hurricane warning for the area including

Turkey Point Nuclear Units 3 & 4. On that basis, a Notice of Unusual Event was declared at 2314 [EDT]. In anticipation of severe weather, the site has completed proceduralized high wind preparations. Our plants have been specifically built to withstand natural disasters such as hurricanes, tornadoes, earthquakes, flooding and tidal surges. This approach will ensure the safety of operations and our employees and the communities surrounding our plants.

"Both units are currently stable at 100% power level.

"The NRC Resident Inspector has been informed."

No safety systems are out of service. The electrical grid is stable but grid risk is high.

<https://www.nrc.gov/reading-rm/doc-collections/event-status/event/2017/20170908en.html>